

PIWNICE

nr	nazwa	F, [m ²]	H, [m]	V, [m ³]	liczba osób	n, [h ⁻¹]	nawiew [m ³ /h]	wywiew [m ³ /h]	uwagi
1	lamus gospodarczy	43,80	2,00	87,60	-	0,5	-	50	

PARTER

nr	nazwa	F, [m ²]	H, [m]	V, [m ³]	liczba osób	n, [h ⁻¹]	nawiew [m ³ /h]	wywiew [m ³ /h]	uwagi
0.1	hall wejściowy	27,25	2,80	76,30	20	1,0	70	-	
0.2	kasa biletowa	4,50	2,80	12,60	1	2,0	-	30	
0.3	hall	58,91	2,80	164,95	?	1,0	160	-	
0.4.1	wc dla kobiet	11,92	2,50	29,80	2	3,2	-	100	
0.4.2	wc dla mężczyzn	8,94	2,50	22,35	3	3,5	-	80	
0.5	pom. gospodarcze	1,72	2,50	4,30	-	2,0	-	20	
0.6	garderoba+zaplecze sanitarne	17,05	2,80	47,74	2	1,0	50	50	
0.7	przedsionek	9,34	2,80	26,15	-	-	-	-	
0.8	komunikacja	30,41	2,80	85,15	-	-	-	-	
0.9	sala kinowa	194,00	5,80	1125,20	145	5,3	6000	5880	
0.10	istn. pom. techniczne (rozdzielnia elektryczna)	5,94	3,00	17,82	-	1,0	-	20	

PIĘTRO

nr	nazwa	F, [m ²]	H, [m]	V, [m ³]	liczba osób	n, [h ⁻¹]	nawiew [m ³ /h]	wywiew [m ³ /h]	uwagi
1.1	zaplecze operatora	28,75	2,92	83,95	2	1,0	90	90	